

**Blended Fuel Compatibility Form**

Facility - 2007026

Facility Name Halsted Super Save
Address 9811 S. Halsted
Chicago, IL 60628
County Cook
Contact Name Khalil Abdullah
Phone Number (773) 779-8005

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Install Date 4/17/2000
Current Product on File Diesel Fuel
Newly Reported Product E85

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	NOV	Manufacturer Approval	FG DW by NOV.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Environ Products/ Environ Geo flex D	Manufacturer Approval	flexpip4+EPA+OUST+Letter+Piping+Suppliers.pdf	
Shear Valve	OPW, 10P-0152E85	Manufacturer Approval	opw+shear+valves.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall STP/Tanktop Sump	Environ	Manufacturer Approval	flexpip4+EPA+OUST+Letter+Piping+Suppliers.pdf	
Single Wall UDC Sump	Environ	Manufacturer Approval	flexpip4+EPA+OUST+Letter+Piping+Suppliers.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root/ Mag probe for alternate fuels	Manufacturer Approval	Veeder+Root+Mag+Probes+for+Alternative+Fluids (1). pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	Fe-petro/MLD	Manufacturer Approval	FFS-0391+MLD++Mechanical+Leak+Detectors+Datasheet. pdf	
Sump Sensor in Double Wall STP/Tanktop Sump	Veeder Root/Veeder-Root 794380-323 position sensitive Sump Sensor	Manufacturer Approval	Veeder%2bRoot%2bSensor%2bCompatibility%2bStatement (1).pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW/OPW 2100C	Manufacturer Approval	OPW-Fuel+Compatibility+Matrix+(Below+Ground) (1).pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EMCO/A1100 ("E" variant) A1100EVR ("E" variant)	Manufacturer Approval	A1100 Fuel Compatibility.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Gilbarco/Encore S dispenser	Manufacturer Approval	Encore_flex_fuel.pdf	We haven't bought the dispenser yet, we will order and install once blended fuel ...
Submersible Turbine Pump	Franklin fueling/4020159	Manufacturer Approval	franklin+stp.pdf	
Nozzle	OPW	Manufacturer Approval	OPW-Fuel+Compatibility+Nozzle+(Above+Ground).pdf	
Hose	VST	Manufacturer Approval	VST-ENVIRO-LOC-Flex-Fuel-Hose_Press-Release-042021 .pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact		☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.
Submitter Name	HAIBAT KHAN	
Job Title	manager	
Company	American Petroleum Solutions	
Phone Number	(909) 312-9449	
Email	apetro.office@gmail.com	