



# OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

## Blended Fuel Compatibility Form

Facility - 5046384

**Facility Name** Caseys General Store  
#3464

**Address** 1002 Sarpy St.  
Morrisonville, IL 62546

**County** Christian

**Contact Name** Jill Reams-Widder

**Phone Number** (217) 526-3433

Tank - 5

**Tank Material** Fiberglass Double Wall

**Tank Capacity** 8,000

**Tank Product** E-85

**Tank Install Date** 6/27/2017

### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval		

### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech S175SC	Manufacturer Approval		
shear valve	EBW 662501902	Manufacturer Approval		
flex connector	Franklin Fueling	Manufacturer Approval		

### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling/ APT	Manufacturer Approval		
Single wall UDC	Franklin Fueling LMM-3617	Manufacturer Approval		

### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root	Manufacturer Approval		
ATG Probe	Veeder Root	Manufacturer Approval		


### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	veeder root	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	veeder Root	Manufacturer Approval		



### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EBW	Manufacturer Approval		

**Overfill Prevention Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EBW	Manufacturer Approval		


**Pump Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible pump	FE Petro	Manufacturer Approval		
Hanging Hardware	Husky	Manufacturer Approval		

**Gaskets & Seals Equipment**

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

**Joint Dopes & Adhesives Equipment**

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe dope	Gasolia	Manufacturer Approval		

**Correspondence Contact**

**Submitter Name** James Franklin  
**Job Title** Construction Manager  
**Company** Seneca Companies  
**Phone Number** (515) 601-6635  
**Email** jfranklin@senecaco.com  
**Contractor License #** IL598

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.