

**Blended Fuel Compatibility Form****Facility - New**

Facility Name Compass Travel Center
Address 3100 N Skokie Highway
North Chicago, IL 60064
County Lake
Contact Name Phil Brauchla
Phone Number (630) 943-1861

Tank - 4

Tank Material Tank - Fiberglass Brine Filled
Double Wall Containment
Solutions
Tank Capacity 6,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval	Containment Solutions Tanks and Sumps.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Single Wall Piping Vent	NOV	Manufacturer Approval	Ameron Piping.pdf	New from Permit Application.
Flexible Double Wall	OPW Flexworks	Manufacturer Approval	OPW Compatibility Matrix.pdf	New from Permit Application.
Flex Connector Steel	Hose Master	Manufacturer Approval	flexibleconnectorsystems (2).pdf	New from Permit Application.
Shear Valves	OPW	Manufacturer Approval	OPW Shear Valve.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions	Manufacturer Approval	Containment Solutions Tanks and Sumps.pdf	New from Permit Application.
Dispenser Sumps	OPW	Manufacturer Approval	OPW Compatibility Matrix.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	New from Permit Application.
ATG Probe	Veeder Root 846391-109	Manufacturer Approval	Veeder Root Probe & Float.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 859080-001	Manufacturer Approval	VR+PLLD+Fuel+Compatibility.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder Root 794380-323	Manufacturer Approval	Veeder Root Sump & Interstitial Sensors.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1-3110	Manufacturer Approval	OPW Compatibility Matrix.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder Root 846391-109	Manufacturer Approval	Veeder Root Probe & Float .pdf	New from Permit Application.
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval	OPW Overfill Prevention Valve.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	FE Petro	Manufacturer Approval	FE Petro Submersible Pump .pdf	
Dispenser	Wayne	Manufacturer Approval	Wayne Dispenser Meter.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gaskets	Wayne	Manufacturer Approval	Wayne Dispenser Meter.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasolila	Manufacturer Approval	Gasolila.pdf	

Correspondence Contact

Submitter Name Nick Bugajsky
Job Title Project manager
Company Stenstrom Petroleum Services Group
Phone Number (630) 606-0996
Email nickb@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.