

**Blended Fuel Compatibility Form**

Facility - 2047075

Facility Name Woodmans Unattended Fuel Station
Address 1515 Deerfield Parkway
Buffalo Grove, IL 60089
County Lake
Contact Name Manny Rios
Phone Number (608) 754-8382

Tank - 3

Tank Material Fiberglass Brine Filled Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 8/20/2020

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval		
Shear Valve	OPW	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump & UDC	S Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor	Incon	Manufacturer Approval		
ATG Probe	Incon	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Incon	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Incon	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Incon	Manufacturer Approval		
Overfill Drop Tube Valve	OPW	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin Fueling	Manufacturer Approval		
Nozzle, Swivel, Breakaway & Hose	Husky & Futura	Manufacturer Approval		

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Adapter	OPW	Manufacturer Approval		

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasola	Manufacturer Approval		

Correspondence Contact

Submitter Name Bob Sumoski
Job Title President
Company Crowne Industries, Ltd.
Phone Number (630) 201-4967
Email bob@crownetank.com
Contractor License # IL002345

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.