

**Blended Fuel Compatibility Form**

Facility - 5007148

Facility Name Circle K #1411
Address 1901 W. Jefferson Street
Springfield, IL 62702
County Sangamon
Contact Name Store Manager
Phone Number (217) 546-4521

Tank - 6

Tank Material Fiberglass Brine Filled Double Wall
Tank Capacity 5,000
Tank Product E-15
Tank Install Date 10/11/2013

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Brine Filled Double Wall	Containment Solutions	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Dualoy 3000/LCX	Manufacturer Approval		
Shear Valves	OPW / 10 Series	Manufacturer Approval		
Flex Connectors	OPW / FC20 Stainless Flex Connector	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Containment Solutions / STP Sump	Manufacturer Approval		
Under Dispenser Containment	Bravo / B7000	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root / 794380-303	Manufacturer Approval		
ATG Probe	Veeder Root / Mag Plus Probe	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root / WPLLD	Manufacturer Approval		
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root - Position Sensitive Sensor 794380-323	Manufacturer Approval		
Under dispenser containment leak detection	Veeder Root - Position Sensitive Sensor 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW / Edge Double Walled Spill Container	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Red Jacket / STP for Alternative Fuels AGP75S1 RJ1	Manufacturer Approval		
Dispenser	Gilbarco / Encore S NA2	Manufacturer Approval		
Nozzle	Husky / EX E85	Manufacturer Approval		
Dispenser Hoses	Continental / Ethan-all E85 559N	Manufacturer Approval		
Dispenser Breakaway	OPW / 66V Breakaway	Manufacturer Approval		
Swivel	OPW / 241TPS-0492	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Brian Niederschmidt

Job Title Estimator

Company Neumayer

Phone Number (636) 515-4517

Email brian_niederschmidt@neumayerequipment.com

Contractor License # IL1502

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.