

**Blended Fuel Compatibility Form**

Facility - 2000428

Facility Name Mohsen Oil, Inc.
Address 24001 W. Lorenzo Road
Wilmington, IL 60481
County Will
Contact Name Nader Arashahi
Phone Number (760) 754-2009

Tank - 10

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E-85
Tank Install Date 2/1/2007

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P175SC	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW	Manufacturer Approval		
Single wall dispenser sump	Franklin APT LMM	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 794380-345	Manufacturer Approval		
ATG Probe	Veeder Root 846391-407	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Mechanical Pressurized Line Leak Detection	FE Petro 403169901	Manufacturer Approval		
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root 577013-933	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Franklin Defender	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Breakaway	OPW 66tec	Manufacturer Approval		
nozzles	OPW	Manufacturer Approval		
Dispenser	Wayne Ovation	Manufacturer Approval		
Hoses	Continental	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Darren White
Job Title Project Manager
Company B&K Equipment
Phone Number (708) 821-5014
Email dj.white@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.