

**Blended Fuel Compatibility Form**

Facility - 4012615

Facility Name Road Ranger #132
Address 4910 N. Market Street
Champaign, IL 61820
County Champaign
Contact Name Jason Martin
Phone Number (815) 540-0688

Tank - 9

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 8/19/2009

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
flex connectors	Franklin Fueling/FLEX-ING	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Transition Sump	OPW polyethylene	Manufacturer Approval		
Double Wall STP/Tanktop Sump	OPW Pisces	Manufacturer Approval		
Single wall UDC	OPW Polyethylene	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Solid state Discriminating Interstitial Monitoring Sensors	Veeder root/ solid state	Manufacturer Approval		
ATG Probe	Veeder Root 450 TLS Mag Plus Probes	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
European with No Test Req Suction	FE Petro STP MLDS+BD	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Double Wall Transition Sump	Veeder Root TLS 450 position sensitive sensor	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Double Wall STP/Tanktop Sump	Veeder Root/ TLS 450	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100 series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW71SOB	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	FE Petro STPAG	Manufacturer Approval		
Dispensers	Gilbarco Encore S	Lab Certification		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Todd Johnston
Job Title Project Manager
Company Road Ranger, LLC
Phone Number (815) 315-2408
Email tjohnston@roadrangerusa.com

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.