From:	David Espinoza
To:	Jacob Lundquist
Subject:	[EXTERNAL] RE: Blue APT STP Sump
Date:	Tuesday, November 2, 2021 2:10:18 PM

Jacob,

It's UL certified to E-100
Under UL 2447

David Espinoza
Technical Service Engineer

Franklin Fueling Systems
3760 Marsh Road
Madison, WI 53718
Phone: +1.800.984.6266
Fax: +1.608.838.6433
www.franklinfueling.com

FFS Pro Support Center
Ask a Technical Question, review Technical Documents and Installation Videos
https://franklinfueling.freshdesk.com/support/home

From: Jacob Lundquist <jlundquist@senecaco.com>
Sent: Tuesday, November 2, 2021 1:56 PM
To: David Espinoza <david.espinoza@franklinfueling.com>
Subject: Blue APT STP Sump

**** External Email ****

Please see the attached picture

Thanks,

Jacob Lundquist
Project Manager
Seneca Companies, Inc
www.senecaco.com

t:563-332-8000 EXT 5730 | m: 563-468-0900
jlundquist@senecaco.com

From: 5634680900@vzwpix.com <5634680900@vzwpix.com>
Sent: Tuesday, November 2, 2021 11:58 AM
To: Jacob Lundquist <jlundquist@senecaco.com>

Subject: [EXTERNAL]

Electronic Transmission Confidentiality Notice
The information contained in this electronic transmission is private, confidential, the property of the sender, and intended for the use of the recipient(s), only. If you are not the addressee, any disclosure, copying, distribution or use of this information for any purpose is strictly prohibited. If you have received this information in error, please notify the sender, **david.espinoza@franklinfueling.com**, immediately by e-mail and then delete this message. Thank you. [FE.EN.1]