



Blended Fuel Compatibility Form

Facility - 6044327

Facility Name Gateway FS, Inc.
Address 409 South Illinois Route 3
 Waterloo, IL 62298
County Monroe
Contact Name Erica Lavallee
Phone Number (618) 282-3454

Tank - 2

Tank Material Composite Double Wall
Tank Capacity 8,000
Tank Product E-85
Tank Install Date 6/12/2009

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval		
Shear Valves	OPW / 10 Series	Manufacturer Approval		
Flex Connectors	OPW / FC20 Stainless Flex Connector	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Under Dispenser Containers	APT Under Dispenser Containment	Manufacturer Approval		
Single Wall STP/Tanktop Sump	APT STP Sump	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root / 794980-430	Manufacturer Approval		
ATG Probe	Veeder Root / 846391 Mag Probe	Manufacturer Approval		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root / ELLD Series 8484	Manufacturer Approval		See page five (5) on document for compatibility table.
Non-Discriminating Sump Sensor in Single Wall STP/Tanktop Sump	Veeder Root / 794380-323	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket Insert	Franklin Fueling / EBW 70245001NC	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Ball Float Vent Valve	EBW 308	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Pump	Franklin Fueling / STP AG	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Brian Niederschmidt

Job Title Estimator

Company Neumayer Equipment, LLC

Phone Number (314) 226-7112

Email brian_niederschmidt@neumayerequipment.com

Contractor License # IL1502

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.