

**Blended Fuel Compatibility Form**

Facility - 2007002

Facility Name Spectrum Food Mart, Inc.
Address 4658 South California
Chicago, IL 60632
County Cook
Contact Name Haney Khalil
Phone Number (708) 257-1201

Tank - 5

Tank Material Tank - Composite Double
Wall Lannon
Tank Capacity 5,000
Tank Product E85
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Lannon	Manufacturer Approval	Lannon Tank Compatibility .pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval	APT XP pipe.pdf	New from Permit Application.
Other Pump	Submersible	Manufacturer Approval	E85 submersible info sheet.pdf	New from Permit Application.
Shear Valves	OPW 10	Manufacturer Approval	opw_eth_compat.pdf	New from Permit Application.
Ball Valves	Morrison	Manufacturer Approval	Morrison ball valve.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo B421	Manufacturer Approval	bravo fiberglass sumps all.pdf	New from Permit Application.
Single Wall UDC Sump	BRAVO B1000	Manufacturer Approval	bravo fiberglass sumps all.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder-Root 794380-430	Manufacturer Approval	veeder root sensors all.pdf	New from Permit Application.
ATG Probe	Veeder-Root 846397-407	Manufacturer Approval	veeder root probes.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder-Root 848480-001	Manufacturer Approval	veeder root plld.pdf	New from Permit Application.
Sump Sensor with positive shutdown	Veeder-Root 794380-323	Manufacturer Approval	veeder root sensors all.pdf	New from Permit Application.

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3112D	Manufacturer Approval	Opw spill containers.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	Emco Wheaton A1100	Manufacturer Approval	EMCO Modular Drop Tubes.p df	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Wayne Ovation2 EB23	Lab Certification	Wayne Ovation EB23.pdf	
Nozzle	OPW 11BP	Manufacturer Approval	opw-11bp-series-ethanol-n ozzles_2018.pdf	
Hose	Goodyear	Manufacturer Approval	Continental_Goodyear_flex steel hoses.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fill cap	OPW	Manufacturer Approval	OPW compatibility.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Thread sealant	Gasola E-Seal	Manufacturer Approval	gasola dope.pdf	

Correspondence Contact

Submitter Name Jim Veverka
Job Title project manager
Company B & K Equipment Company
Phone Number (708) 474-3344
Email jim.veverka@bkequip.com
Contractor License # IL1207

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.