



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 7042092

Facility Name Love's Travel Stop #318
Address 202 North Ave.
Ina, IL 62846
County Jefferson
Contact Name Jamey Fowlkes
Phone Number (405) 302-6640

Tank - 7

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 7/26/2012

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	biofuel-compatibility+CSI+tanks.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Dualoy	Manufacturer Approval	Dualoy+3000+LCX+Data+Sheet.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
UDC	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3 B99 & E85.pdf	
Transition Sumps	Bravo	Manufacturer Approval	Bravo_Sumps_AlternativeFuels_R3 B99 & E85.pdf	
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	bravo_afton (1).pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder-Root	Manufacturer Approval	577014-449-01_Aluminum_Mag_Plus_In-Tank_Probe.pdf	
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root 07944380-345	Manufacturer Approval	!!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	From Permit Application

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder-Root	Manufacturer Approval	Veeder Root-PLLD compatibility sheet.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder-Root 0794380-321	Manufacturer Approval	!!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW	Manufacturer Approval	OPW+1-2105+compatibility+ sheet (2).pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Alarm	Veeder-Root	Manufacturer Approval	576047-241_Overfill_Alarm .pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	Red Jacket	Manufacturer Approval	!!!!Veeder-Root - Fuel Compatibility Letter - Executed - 2015-09-23 (2).pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Anthony Mannino
Job Title Project Manager
Company Illinois Oil Marketing Equipment
Phone Number (309) 202-0792
Email amannino@iome.com
Contractor License # IL1293

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.