



Blended Fuel Compatibility Form

Facility - 2045776

Facility Name Lenny's Food N Fuel Harlem Avenue, LLC
Address 19420 S. Harlem Avenue
 Tinley Park, IL 60477
County Will
Contact Name Josh Kantor
Phone Number (815) 469-4100

Tank - 2

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 5/21/2015

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Lab Certification	Xerxes.pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valves	opw 10series	Lab Certification	OPW Drop tube Adapters Im pact Valves.pdf	
Flex Connectors	Franklin	Lab Certification	Fire flex flexes.pdf	
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Lab Certification	Ameron Piping.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
UDC	B1000 UDC	Lab Certification	Bravo Sumps.pdf	
Single Wall STP/Tanktop Sump	Xerxes	Lab Certification	Xerxes Containment Sump U pgrades (1).pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root 794380-345	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root plld	Manufacturer Approval	e85 plld.pdf	
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root	Lab Certification	Veeder Root Sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	opw	Lab Certification	Edge Spill bucket.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	opw	Lab Certification	OPW Drop tube Adapters Im pact Valves.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco Dispensers	Gilbarco	Lab Certification	Gilbarco.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Steve Kryl

Job Title Project Manager

Company Anderson Pump Service, Inc.

Phone Number (708) 243-9081

Email steve@andersonpump.com

Contractor License # IL002275

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.