



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 1033835

Facility Name Petro Center Rochelle
Address 900 Petro Drive
Rochelle, IL 61068
County Ogle
Contact Name Jill Sanders
Phone Number (815) 562-8475

Tank - 14

Tank Material Tank - Composite Double
Wall Modern Welding Glasteel
II
Tank Capacity 8,000
Tank Product B-99
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Modern Welding Glasteel II	Manufacturer Approval	Glasteel II Brochure_2.pdf	New from Permit Application.

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	OPW CXXA Double wall Piping	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	New from Permit Application.
Flex Connector Steel	OPW	Manufacturer Approval	12-flexing_biodiesel.pdf	New from Permit Application.
Fiberglass Single Wall Piping single wall vent	Ameron Fiberglass 4000 L	Manufacturer Approval	10-NOV.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW Fiber Galss Sump	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	New from Permit Application.
Single Wall UDC Sump	OPW Fiber Glass Sump	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root- 0794380-430	Manufacturer Approval	577013-750-16_AE.pdf	New from Permit Application.
ATG Probe	Veeder Root-889560	Manufacturer Approval	18-Veeder-Root Fuel Compatibility Letter - Executed - 2015-09-23.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veer Root-794380-321	Manufacturer Approval	577013-750-06_AF.pdf	New from Permit Application.
Sump sensors with positive shut down	Veeder Root-794380-345	Manufacturer Approval	18-Veeder-Root Fuel Compatibility Letter - Executed - 2015-09-23.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW Edge Series 3100	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	New from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SO-B High Bio Diesel	Manufacturer Approval	opw-fuel-compatibility-matrix-below-ground-products-2018.pdf	New from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser	Encore Ultra High flow	Manufacturer Approval	13-Encore UL Approval_Bio Diesel.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasolia	Gasolia	Manufacturer Approval	11-GASOILA-TDS-hard-set.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dopes and Adhesives	Bravo Systems	Manufacturer Approval	16-Bravo_Fittings_AlternativeFuels_R3.pdf	

Correspondence Contact

Submitter Name Ravindra Penmatsa
Job Title President
Company America Petropump Services LLC d/b/a Ampsco Services
Phone Number (312) 286-6722
Email ravi@ampsco.net
Contractor License # IL002420

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.