

**Blended Fuel Compatibility Form**

Facility - 2001587

Facility Name Ricky Rockets
Address 14640 S. Cicero Ave.
Midlothian, IL 60445
County Cook
Contact Name Eric Gaowski
Phone Number (630) 894-0099

Tank - 8

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E85
Tank Install Date 11/18/2016

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Fluid Containment Brine Filled	Manufacturer Approval	E85 tanks.pdf	Fluid Containment same as Containment Solutions

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Shear Valve	opw 10 series	Manufacturer Approval	10 Series Emergency Shut- Off Valves _ OPW Retail F ueling.pdf	
Ameron/NOV	Double wall	Manufacturer Approval	NOV RedThreadAlcohol Comp atibility.pdf	
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	NOV RedThreadAlcohol Comp atibility.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Tank Sump	xerxes	Manufacturer Approval	E85 tanks.pdf	Tank sumps part of tanks
UDC Sump	Bravo B1000	Manufacturer Approval	Bravo_Sumps_AlternativeFu els_R3.pdf	
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval	Bravo Sumps.pdf	
Single Wall UDC Sump	Bravo	Manufacturer Approval	Bravo Sumps.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
ATG Probe	Veeder Root 846391	Manufacturer Approval	846391 E85 probe.pdf	
Hydrostatic Reservoir Interstitial Monitoring Sensors	Veeder Root 794380-303	Manufacturer Approval	Veeder-Root Sensor Guide. pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	848480-001	Manufacturer Approval	veeder root 848480-001 PL LD.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder-Root 794380-323	Manufacturer Approval	Veeder-Root Sensor Guide. pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	Franklin Defender	Manufacturer Approval	Franklin Defender.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71S0M	Manufacturer Approval	71S0.pdf	Original permit had typo/clerical error. OPW 71S0M was used.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible Turbine Pump	Franklin FE Petro 4"	Manufacturer Approval	Franklin submersible.pdf	
Dispenser	Gilbarco Encore 700S NL1	Manufacturer Approval	Gilbarco Dispensers.pdf	
Nozzle	OPW 11	Manufacturer Approval	E85 nozzle.pdf	
Hose	Flexsteel Futura	Manufacturer Approval	Contitech ethanol hose 02 0617.pdf	

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Keenan Ary

Job Title Pipefitter

Company Anderson Pump Service, Inc.

Phone Number (630) 484-7374

Email KeenanA@andersonpump.com

Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.