



Blended Fuel Compatibility Form

Facility - 5038551

Facility Name Road Ranger #266
Address 700 King Road
P.O. Box 408
New Berlin, IL 62670
County Sangamon
Contact Name John Carabelli
Phone Number (815) 387-1700

Tank - 5

Tank Material Fiberglass Double Wall
Tank Capacity 20,000
Tank Product B-99
Tank Install Date 10/18/2012

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval		
flex connectors	Franklin Fueling/FLEX-ING	Manufacturer Approval		
Shear Valves	OPW 10 series	Manufacturer Approval		

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo	Manufacturer Approval		
Single wall UDC	Bravo	Manufacturer Approval		

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Discriminating Interstitial Monitoring Sensors	Veeder root 450 / solid state discriminating sensor	Manufacturer Approval		
ATG Probe	Veeder Root Mag Plus Probes	Lab Certification		

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
European with No Test Req Suction	FE Petro STP MLDS+BD	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root TLS 450 position sensitive sensor	Manufacturer Approval		

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	OPW 1-2100 series	Manufacturer Approval		

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW71SO-B	Manufacturer Approval		

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
STP	FE Petro STPAG75	Manufacturer Approval		
Dispensers	Gilbarco Encore S	Manufacturer Approval		

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Todd Johnston
Job Title Project Manager
Company Road Ranger L.L.C.
Phone Number (815) 315-2408
Email tjohnston@roadrangerusa.com

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.