



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 2047072

Facility Name Lenny's Gas N Wash Gouger
Road, LLC
Address 15930 W 159th Street
Homer Glen, IL 60491
County Will
Contact Name Cherrie Tompkins
Phone Number (708) 805-2525

Tank - 3

Tank Material Fiberglass Double Wall
Tank Capacity 10,000
Tank Product E85
Tank Install Date 9/11/2020

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	e85 containment solutions .pdf	

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Ameron Dualoy 3000/LCX	Manufacturer Approval	e85 frp pipe.pdf	
Shear Valve	opw 10p	Manufacturer Approval	e85 shear valve.pdf	

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Bravo B421	Manufacturer Approval	e85 bravo.pdf	
Single Wall UDC Sump	Bravo B1000	Manufacturer Approval	e85 bravo.pdf	

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors With Monitor	Veeder Root 794380-345	Manufacturer Approval	E85 sensors.pdf	New from Permit Application.

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root 848480-001	Manufacturer Approval	e85 plld.pdf	
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root 794380-323	Manufacturer Approval	E85 sensors.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	FE Petro Defender 705555112CI-GKT	Manufacturer Approval	e85 franklin spill.pdf	

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-410M	Manufacturer Approval	e85 drop tube.pdf	

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispensers	Gilbarco Encore700S	Manufacturer Approval	e85 gilbarco.pdf	
Submersible Turbine Pump	fe petro	Manufacturer Approval	e85 franklin all.pdf	
Nozzle	opw 21gu-0992-e85	Manufacturer Approval	e85 opw all.pdf	
Hose	Continental Hose 53233712412169	Manufacturer Approval	e85 contental hose.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
None that are not part of an approved divice	None that are not part of an approved device.	Not Applicable		None that are not part of an approved device.

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gasoila E Seal	Gasoila E Seal	Manufacturer Approval	e85 dope.pdf	

Correspondence Contact

Submitter Name

Stephen Kryl

Job Title

Project Manager

Company

Anderson Pump Service, Inc.

Phone Number

(708) 243-9081

Email

steve@andersonpump.com

Contractor License #

IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.