

**Blended Fuel Compatibility Form**

Facility - 1046660

Facility Name Speedway #3962
Address 5951 E. Rockton Road
Roscoe, IL 61073
County Winnebago
Contact Name Sally Walsh
Phone Number (815) 389-4920

Tank - 8

Tank Material Fiberglass Double Wall
Tank Capacity 6,000
Tank Product E-85
Tank Install Date 7/24/2018

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions Double Wall Fiberglass	Manufacturer Approval		From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Universal Petro Pipe	Manufacturer Approval		Letter of Manufacture Compatibility
OPW Shear Valve	10P-0152-E85	Manufacturer Approval		Boucher of Shear Valve showing compatibility
Flex Connector	Flexing	Manufacturer Approval		Broucher of Flex Connector Highlighted showing compatibility

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	Franklin Fueling LMM-3915	Manufacturer Approval		Sumps installed at this facility are Franklin Fueling APT LM-3915-HLX that attac...
Tank Containment Sumps	Containment Solutions Single Wall Fiberglass Sumps on tanks	Manufacturer Approval		Containment Solutions Single Wall Fiberglass Sumps

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root	TLS-450 Plus	Manufacturer Approval		From Permit Application
ATG Probe	Veeder Root Mag Plus	Manufacturer Approval		From Permit Application

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder Root Sump Sensors Model # 794380-323	Manufacturer Approval		Sump Sensors for E-85
ELLD	Veeder Root PLLD 848480-003	Manufacturer Approval		Line Leak Detectors

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW 1C-3112P	Manufacturer Approval		From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM-412C	Manufacturer Approval		From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submerge Pump	2 HP AG	Manufacturer Approval		From Permit Application

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Doug Harmon
Job Title Project Manager
Company Stenstrom
Phone Number (708) 485-4105
Email dough@rstenstrom.com
Contractor License # IL1890

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.