

**Blended Fuel Compatibility Form****Facility - New**

Facility Name QT #7190
Address 4501 Veterans Memorial
Drive
Mount Vernon, IL 62864
County Jefferson
Contact Name Cody Thiems
Phone Number (918) 615-7304

Tank - 5

Tank Material Tank - Fiberglass Double Wall
Containment Solutions
Tank Capacity 18,000
Tank Product B-99
Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	Containment Solutions	Manufacturer Approval	containment solutions bio fuel-compatibility (3).pdf	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Universal Petro Pipe	Manufacturer Approval	FFS-0164 (UL) UPP Semi-Rigid Pipework System Datasheet.pdf	From Permit Application
Flex Connector Steel	Omega	Manufacturer Approval	OmegaFlex Statement of Compatibility - Flex Connectors REV 4-19.pdf	From Permit Application
Other Pump	Submersible	Manufacturer Approval	FE Petro STPAG.pdf	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	containment solutions	Manufacturer Approval	containment solutions bio fuel-compatibility (3).pdf	From Permit Application
Single Wall Transition Sump	Containment Solutions	Manufacturer Approval	containment solutions bio fuel-compatibility (3).pdf	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Hydrostatic Reservoir Interstitial Monitoring Sensors	VEEDER ROOT 794380	Manufacturer Approval	794380-345 Interstitial Sensor Solid-State Alternative Ethanol Fluid Interstitial Sensor_for_Double-Wall_Fiberglass_Tanks.pdf	From Permit Application
ATG Probe	veeder root 846391	Manufacturer Approval	846391-xxx Stainless Steel Mag Plus In-Tank Probe Alternative Fluids.pdf	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 794380-351	Manufacturer Approval	Veeder Root 794380-351 B100 Compatible.pdf	From Permit Application
EPLLD	veeder root 859080	Manufacturer Approval	DPLLD 859080_Electronic_Pressurized_Line_Leak_Detection_Datasheet.pdf	

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW	Manufacturer Approval	OPW 1-3100 Spill Bucket B io Compatible.pdf	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW 71SOM	Manufacturer Approval	OPW Tank Equipment Compat ibility.pdf	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
dispenser pumps	Gilbarco Encore	Manufacturer Approval	Gilbarco Encore Dispenser s Bio Compatible.pdf	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
GASKETS & ORINGS	GILBARCO	Manufacturer Approval	Gilbarco Encore Dispenser s Bio Compatible.pdf	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
SEALANT	Gasiola	Manufacturer Approval	Gasola Compatability.pdf	

Correspondence Contact**Submitter Name** Heather Hinds**Job Title** Construction**Company** Neumayer Equipment Company**Phone Number** (314) 210-5036**Email** HEATHER_HINDS@NEUMAYEREQUIPMENT.COM**Contractor License #** IL1502☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.