

**Blended Fuel Compatibility Form**

Facility - 2017674

Facility Name Rawa Midwest Convenience, Inc.
Address 5550 West 79th Street
Burbank, IL 60459
County Cook
Contact Name Kim Murff
Phone Number (708) 624-0112

Tank - 10

Tank Material Fiberglass Double Wall
Tank Capacity 8,000
Tank Product E85
Tank Install Date 9/17/2015

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
XERXES DOUBLE TANK	XERXES	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	TANK is existing

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Other Riser	Steel	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	New from Permit Application.

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Not Installing sumps	OPW	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	Not Installing sumps

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root Tank Probe	Veeder Root 846391-407	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	Not installing ATG Probes

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Veeder Root Tank Probe	OPW	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	Not installing sump sensors or line leak detectors

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	OPW	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	Replacing from Permit Application.

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	Replacing from Permit Application.

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Dispenser is existing	Existing	Manufacturer Approval	OPW FUEL COMPATIBILITY SH EET 8-15-2025.pdf	Not installing a new Dispenser

Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

Correspondence Contact

Submitter Name Keith Duda

Job Title Project Manager

Company Anderson Pump Service, Inc.

Phone Number (708) 560-5590

Email Keith@Andersonpump.com

Contractor License # IL002275

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.