



OFFICE OF THE ILLINOIS STATE FIRE MARSHAL

Blended Fuel Compatibility Form

Facility - 3000811

Facility Name Blick & Blick Oil, Inc.

Address 203 SE 5th Ave.
Aledo, IL 61231

County Mercer

Contact Name Steve Blick

Phone Number (309) 582-2012

Tank - 12

Tank Material Tank - Composite Double
Wall Glasteel II

Tank Capacity 4,000

Tank Product E-85

Tank Install Date Not Installed

Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Composite Double Wall	Glasteel II	Manufacturer Approval	20211215131136307...	From Permit Application

Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	A.P.T. Poly Tech P150SC	Manufacturer Approval	20211215131243718...	From Permit Application
Positive Shutoff Valves	Veeder Root TLS 450 with DPLLD	Manufacturer Approval	20211215131544001...	From Permit Application
Shear Valves	EBW 662500902	Manufacturer Approval	20211215131712621...	From Permit Application

Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Transition Sump	APT AST-2922	Manufacturer Approval	20211216140411170...	From Permit Application
Single Wall STP/Tanktop Sump	APT TSM-W-4736	Manufacturer Approval	20211216140411170...	From Permit Application

Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	veeder root 0794381-333	Manufacturer Approval	20211216143725007...	From Permit Application
ATG Probe	Veeder Root 0846397-108	Manufacturer Approval	20211216144145488...	

Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root DPLLD	Manufacturer Approval	20211215131544001...	From Permit Application
Non-Discriminating Sump Sensor with positive shutdown	Veeder Root 0794380-323	Manufacturer Approval	20211216143738790...	From Permit Application

Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
--------------------	--------------------	----------------------	---------------	---------

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Double Wall Spill Bucket	EBW 705556122	Manufacturer Approval	20211216144632903...	From Permit Application

Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	EBW 708591921	Manufacturer Approval	20211216144912221...	From Permit Application

Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Submersible pump	Franklinstpag150	Manufacturer Approval	20211216145152572...	

Gaskets & Seals Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
entry boots	APT feb-150d	Manufacturer Approval	20211216150547399...	

Joint Dopes & Adhesives Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Pipe Dope	Gasolia-100	Manufacturer Approval	20211216150115315...	

Correspondence Contact

Submitter Name Roger Clark
Job Title President
Company Central Petroleum Equipment Company
Phone Number (563) 381-5092
Email rogerpec@revealed.net
Contractor License # IL345

☒ By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.