



### Blended Fuel Compatibility Form

<b>Facility - 2002267</b>	<b>Tank - 8</b>
<b>Facility Name</b> Speedway #7422	<b>Tank Material</b> Fiberglass Double Wall
<b>Address</b> 7859 S. Harlem Avenue Burbank, IL 60459	<b>Tank Capacity</b> 4,000
<b>County</b> Cook	<b>Tank Product</b> E-85
<b>Contact Name</b> Rob Vondras	<b>Tank Install Date</b> 5/9/2014
<b>Phone Number</b> (708) 430-2227	

#### Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Fiberglass Double Wall	XERXES	Manufacturer Approval		

#### Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Flexible Double Wall	Franklin Fueling Systems UPP	Manufacturer Approval		

#### Containment Sump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall STP/Tanktop Sump	OPW-Flexworks	Manufacturer Approval		
Single wall UDC	OPW-Flexworks	Manufacturer Approval		

#### Release Detection Tank Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Non-Discriminating Interstitial Monitoring Sensors	Veeder Root-794380-345	Manufacturer Approval		
ATG Probe	Veeder Root-846391-407	Manufacturer Approval		

#### Release Detection Piping Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Electronic Pressurized Line Leak Detection	Veeder Root-859080-001	Manufacturer Approval		
Non-Discriminating Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Veeder-root 794380-323	Manufacturer Approval		

#### Spill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Single Wall Spill Bucket	EMCO-A1000	Manufacturer Approval		

#### Overfill Prevention Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Overfill Drop Tube Valve	OPW-71SOM	Manufacturer Approval		
Overfill Alarm	Veeder Root-7900091-001	Manufacturer Approval		

#### Pump Equipment

Compatibility Item	Model/Manufacturer	Compatibility Method	Documentation	Comment
Gilbarco-Encore	Gilbarco Flex Dispenser	Manufacturer Approval		

#### Gaskets & Seals Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Joint Dopes & Adhesives Equipment

No documentation submitted - Not Required for tanks installed prior to 10/13/2018

#### Correspondence Contact

**Submitter Name** Ravindra Penmatsa  
**Job Title** Business Director  
**Company** Ampsco services  
**Phone Number** (312) 286-6722  
**Email** ravi@ampsco.net

By checking this box, I certify that this Blended Fuel Compatibility Form has been completed as required by OSFM rules.