



Veeder-Root Company

125 Powder Forest Drive
Post Office Box 2003
Simsbury, CT 06070
USA
Tel: 860-651-2700
Fax: 860-651-2719
www.veeder.com

March 10, 2014

Subject: Veeder-Root Fuel Compatibility Statement

Veeder-Root Company equipment is compatibility with the percent content of the listed alternative fuels.

Equipment Type	Series or Part Number (P/N)	Ethanol %	Biodiesel % ASTM 6751 ASTM 7467
Magnetostrictive Probe	Mag Plus Series 8463X0 Mag Series 8473X0	15%	20%
Magnetostrictive Probe Alternative Fuel	Mag Plus Series 8463X1 Mag Series 8473X1	90%	100%
Tall Tank Probe	Mag-FLEX 889560-XXX, MAGXL-XXX	90%	100%
Continuous Interstitial Tank System	P/N 857280-100, 857280-200, 857280-30X, 332175-001	15%	20%
Electronic Line Leak Detector	Series 8475, 8484, 8494, 8590	15%	20%
Ground Water Monitoring	P/N 794380-621, 794380-622, 794380-624	15%	20%
Interstitial Monitoring	P/N 794380-XXX, 794390-XXX, 847990-00X, 857060-XXX, 857080-XXX	15%	20%
Interstitial Monitoring	P/N 794380-323, 794380-333, 794380-344, 794380-345, 794380-430	85%	20%
Vapor Monitoring	P/N 394390-700	15%	20%

Note: "X" can be substituted for any value.

The basic standard used to investigate products in UL Product category EQXX is ANSI/UL 1238 – Control Equipment for Use with Flammable Liquid Dispensing Devices. These devices are intended for use in accordance with the applicable standards of the National Fire Protection Association, including ANSI/NFPA 30 – Flammable Combustible Liquids Code.

Feel free to contact us if further assistance or clarifications are needed.

Dale Spence
Director, Global ATG Products
Veeder-Root Company
Tel: 860-651-2721
Fax: 860-651-2719